

FIRE SAFETY CERTIFICATE

No.

Dated: 26/11/2024

Certified that the E Kasila Education Society (name of the building or premises) at 1-7-1003 Hunter Road, Hanamakonda (address) comprised of basement(s) and Ground, First, Second & Third floor (upper floors) owned/ occupied by Warangal Public School, Hunter Road, TS (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 26/11/2024 (date of inspection) in the presence of Capt. V. Lakshminarayana Rao (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes I (7th) (XI/ XII) With effect from 26/11/2024 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Annual Fire Safety Inspection conducted and found
2. Satisfactory
- 3.
- 4.

Issued on 26-11-2024 (date of issue) at Hanamakonda (place) by

*Strike out whichever is not applicable.

Signature with Seal: [Signature]
 District Fire Officer
 Fire Prevention Wing
 Municipal Corporation, Warangal
 Name (S. SHANKAR LINSAM)
 Designation DISTRICT FIRE OFFICER.
 Name & Address of Department/ Office: Greater Warangal Municipal Corporation, Warangal

To

Warangal Public School,
#1-7-1401, 1-7-1402,
 (Name & Address of the Institution)
Hunter Road, Hanamakonda

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to
 (reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]
 Secretary & Correspondent
WARANGAL PUBLIC SCHOOL
 HUNTER ROAD, HANAMKONDA, WARANGAL

[Signature]
 Principal
WARANGAL PUBLIC SCHOOL
 Hunter Road, Hanamakonda, TS

Principal
WARANGAL PUBLIC SCHOOL
Hunter Road, Warangal, TS

Principal
WARANGAL PUBLIC SCHOOL
Hunter Road, Warangal, TS

GREATER WARANGAL MUNICIPAL CORPORATION

From
The Commissioner
Greater Warangal Municipal Corporation
Warangal

To
Vodithala Lakshmi Kantha Rao
H.No.1-108, Singapur
Huzurabad, Karimnagar

RC.No.HO/GWMC/DFO/E-143006/ SCHL/2024, Date:26.11.2024

Sub: - Greater Warangal Municipal Corporation – Fire Prevention Wing – Renewal of Fire No Objection Certificate for occupancy to the Non - MSB of M/s Warangal Public School, H.No. 1-7-1041 & 1-7-1042, Hunter Road, Hanumakonda Mandal & District - Reg.

Ref: - 1. RC.No.5041/B2/97, Dt: 12-03-2010 of Director General, A.P. State Disaster Response and Fire Services, A.P Hyderabad.
2. Application of the Principal, Warangal Public School, Dt: 11.11.2024.
3. Renewal of No objection certificate for occupancy vide Rc.No.HO/DFO/ E-138686/GWMC/SCHL/2023, Date: 13.12.2023.
4. Note approval of the Commissioner, GWMC, Warangal in eoffice file No.143006 dated:26.11.2024.

Vide reference 2nd cited above, the Principal, Warangal Public School submitted an application for requesting to issue renewal of NOC for occupancy to the M/s Warangal Public School, H.No. 1-7-1041 & 1-7-1042, Hunter Road, Hanumakonda mandal & district. Under the powers delegated vide ref. 1st cited, the Officers of Fire Prevention Wing, GWMC Warangal have inspected the above school on 13.11.2024 and submitting the following report.

The management has obtained renewal of fire no objection certificate for occupancy vide reference 3rd cited to the Non Multi storied building with Ground+3 Upper Floor with a height of 11.50 Mts & 14.75 Mts for educational occupancy (B1).

1. Particulars of the Building

- a) Total Plot area /Ht. Of Buildings : 5611.65 Sq. Mts / 11.50 Mts & 14.75 Mts
b) No. Of Blocks / Floor : One Block Square Shape / G+2 & Ground+3 Upper Floors Partially
c) Type of occupancy : Educational (B1)
d) Open Spaces & Gate Width

3	Sl.No.	Open Spaces	Required as per occupancy NOC	Provided Now	Deficit
a	1	NORTH	3.00 Mts	3.00 Mts	-----
	2	SOUTH (Front)	10.00 Mts	10.00 Mts	-----
	3	EAST	8.00 Mts	8.00 Mts	-----
	4	WEST	4.00 Mts	4.00 Mts	-----

b	Sl.No.	Gate Width (As per NBC 2005)	Required	Provided	Deficit
	1	Entry gate width	4.50 Mts	4.50 Mts	-----
	2	Entry Gate Head Clearance	5.00 Mts	5.00 Mts	-----

g) Means of Escape & Floor Wise Details

Sl. No.	Floor Wise Details				Means of Escape	
	Floor Type	Type of Occupancy	Built Up Area in Sq. Mts	Occupant Load	Required	Provided
1	Ground Floor	Educational (B1)	1466.72	235	4.65 Mts	4.65 Mts
2	First Floor	Educational (B1)	1466.72	225	4.65 Mts	4.65 Mts
3	Second Floor	Educational (B1)	1466.72	225	4.65 Mts	4.65 Mts
4	Third Floor	Educational (B1)	330.30	75	1.50 Mts	4.65 Mts

f) Stair Cases (As per NBC 2005)

Sl. No.	Type of Staircase	No. of Staircases	Width	Floor from	Floor to
1	Internal Staircase1	1 No's	1.15 Mts	Ground	Terrace
2	Internal Staircase2	1 No's	1.70 Mts	Ground	Terrace
3	Internal Staircase3	1 No's	1.80 Mts	Ground	Terrace

e) Travel Distance & Dead end of the corridor

Sl. No.		Required	Provided	Deficit
1	Farthest point (Most Remote Point) Within a storey or a mezzanine floor to the door to an Exit.	30 Mts	30 Mts	-----
2	The Dead end of the corridor length in exit access. (not exceeding 06 meters for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00 Mts	6.00 Mts	-----

h) Fire Fighting Installations as per Table 7 of NBC 2005

Sl. No.	Fire Fighting System	Required	Provided
1	Fire Extinguishers	28 No's	28 No's
2	First Aid Hose Reel	7 No's	7 No's
3	Terrace Tank	10,000 Lts	10,000 Lts
4	Terrace Pump/ Booster Pump	450 LPM	450 LPM
5	Down Commers	2 No's	2 No's

The management has remitted fire prevention fee vide GWMC Cash receipt No. 141211 Dt: 13.11.2024 for Rs. 10,000/- (Rupees Ten thousand only).


In view of the above renewal of no objection certificate for occupancy to the above existing Non multi storied building from Fire Safety Point of View issued subject to the following conditions.

1. The NOC issued is confined to the Fire Safety measures to be installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/ Occupancy or building Regularization. The owner / Occupier shall comply the Building Rules Govt. Orders as applicable.
2. Evacuation plan showing exist routes and recommended action plan be displayed at conspicuous locations and shall be exhibited at all times, all escape / exit routes shall not be locked or encroached
3. Fresh NOC would be required for any change in occupancy or addition / alterations in the building structure as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection
5. Any Loss of life or property due to Non- functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. Additional/Alteration, if any, in the building may be verified by building authority.
8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The renewal of fire No objection certificate for occupancy is valid for the period of 1(One) years i.e., from 26-11-2024 to 25-11-2025, its responsibility of the owner/occupier to apply renewal of fire No Objection Certificate one month before expiry of above fire No Objection Certificate.

This is approved by the Commissioner, GWMC Warangal vide e-office file number 143006, Dt.:26.11.2024.

**Sd/- Ashwini Tanaji Wakade, I.A.S,
Commissioner,
Greater Warangal Municipal Corporation,
Warangal.**


District Fire Officer
Fire Prevention Wing
Municipal Corporation, Warangal
26/11/2024

